


# Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Umweltmedizin  
Direktor: Prof. Dr. rer. nat. L. Dunemann



Hygiene-Institut · Postfach 10 12 55 · 45812 Gelsenkirchen

SBF – HAGUSTA GmbH  
Schwarzwaldstr. 7  
77871 Renchen

Rotthäuser Str. 19  
45879 Gelsenkirchen

Phone (0209) 9242-230  
Fax (0209) 9242-222  
E-Mail c.schell@hyg.de  
Internet www.hyg.de

Reference: W-159967e-08-SI  
Responsible: Frau Dr. Ch. Schell

Gelsenkirchen, 29.02.2008

## TEST CERTIFICATE

**Enhancement of Microbial Growth on Materials to Come into Contact with Drinking water  
pursuant to DVGW Technical Standard, November 2007**

**Client:** SBF – HAGUSTA GmbH  
Schwarzwaldstr. 7  
77871 Renchen


**Test material:** HAGULIT

**Test method:** Material test

According to test report **W-159967e-08-SI** from 29.02.2008, the afore mentioned material is conform to the requirements for the use in the area of drinking water systems pursuant to DVGW Technical Standard W 270. The test results are itemized in the test report.

This test certificate shall become valid upon date of issue and shall expire on **29.01.2013** provided that conditions and requirements remain unaltered. Upon these conditions the validity may be extended on application up to another 5 years term.

Director of the Institute  
On behalf

  
Dr. Ch. Schell

(Abteilung Wasserhygiene und Umweltmikrobiologie)



The test results and assessments refer exclusively to the examined test specimens and the existing regulations.  
The validity of this document expires in case of modifications in the composition of the material or the processing conditions.  
The present document may only be published and reproduced unabridged and unaltered.  
This document is no DVGW-certification.



DAP-PL-2548.00