



GWE pumpenboese GmbH
Postfach 60 28
31215 Peine

Rotthäuser Str. 19
45879 Gelsenkirchen

Phone (0209) 9242-230
Fax (0209) 9242-222
E-Mail c.schell@hyg.de
Internet www.hyg.de

Reference: W184720e-09-SI
Responsible: Mrs. Dr. Ch. Schell

Gelsenkirchen, 07.12.2009

TEST CERTIFICATE

**Enhancement of Microbial Growth on Materials to Come into Contact with Drinking water
Test pursuant to DVGW Technical Standard, November 2007**

Client: GWE pumpenboese GmbH
Postfach 60 28
31215 Peine

Test material: PVC-K-Rohr

Test method: Material test

According to test report **W-184720e-09-SI** of 07.12.2009, the afore mentioned material **PVC-K-Rohr** is conform to the requirements for the use in the area of drinking water systems pursuant to DVGW Technical Standard W 270. Details to test run and test results are itemized in the test report.

This test certificate shall become valid upon date of issue and shall expire on **07.12.2014** if conditions and requirements remain unaltered. The validity may be extended on application up to another 5 years term provided that the specifications of Technical Standard W 270 are met.

Director of the Institute
On behalf


Dr. Ch. Schell
Department of Water Hygiene and Environmental Microbiology



The test results and assessments refer exclusively to the examined test specimens and the existing regulations.
The validity of this document expires in case of modifications in the composition of the material or the processing conditions.
The present document may only be published and reproduced unabridged and unaltered.
This document is no DVGW-certification.

